

KITSAP COUNTY BOARD OF HEALTH ORDINANCE 2008A-01

ONSITE SEWAGE SYSTEM AND GENERAL SEWAGE SANITATION REGULATIONS

**Policy #32: Aerobic Treatment Unit tank requirements**

**Effective Date: June 9, 2015**

**Purpose:** The purpose of this policy is to establish the design and installation requirements for onsite sewage systems which utilize an aerobic treatment unit (ATU). The policy is meant to minimize the amount of future system pumping, and maximize the amount of treatment the ATU can provide.

**Policy:** A 1,000 gallon trash trap tank will be utilized prior to the ATU device. When it is not possible to locate a trash trap tank, at the discretion of the Health Officer, a smaller tank may be utilized (minimum 500 gallon) or the tank may be removed from the design.