



Title: Stake-out Requirements for OSCAR Drainfields	Page 1 of 1
Number: [Administrative] Policy OS-40	Effective Date: June 1, 2024
Applies To: Approval & Installation of OSCAR Drainfields	Supersedes: N/A
Approved: Eric Evans, Assistant Environmental Health Director	Next Review: As Needed

Purpose: The purpose of this policy is to establish the procedures for obtaining approval to install an OSCAR drainfield in Kitsap County.

Policy: The OSCAR design manuals require that all OSCAR coils be installed on contour. All coils must be on the same plane and have the same depth of sand under each coil. In order to ensure that a site is suitable for an OSCAR drainfield, the following procedures must be adhered to.

1. Any septic designer or professional engineer proposing an OSCAR drainfield shall:
 - A. Clear the proposed drainfield area, including trees located within the basal area.
 - B. Stake-out all four corners of the proposed drainfield area.
 - C. Provide elevations of all four corners of the proposed drainfield area.

2. Any installer who takes out a permit to install an OSCAR drainfield that was approved prior to April 22, 2024 shall:
 - A. Clear the proposed drainfield area, including trees located within the basal area.
 - B. Stake-out all four corners of the proposed drainfield area.
 - C. Provide elevations of all four corners of the proposed drainfield area.
 - D. Call the Health District for an inspection prior to beginning installation.