



Title: UV Disinfection Device Installation Requirements	Page 1 of 1
Number: [Administrative] Policy OS-17	Effective Date: March 17, 2025
Applies To: UV Disinfection Devices for OSS	Supersedes: N/A
Approved: Eric Evans, Assistant Environmental Health Director	Next Review: As Needed

Purpose: The purpose of this policy is to establish the procedures for installing UV disinfection devices.

Policy: The following policy and procedures shall be followed when installing UV disinfection devices.

1. The UV device(s) shall:
 - A. Be installed in the pump tank when only a single UV disinfection device is required.
 - B. Shall be installed to receive equal flow from a device such as a distribution box when more than one UV disinfection device is required.
 - C. Be installed in a manner to ensure that water intrusion does not occur.
 - D. Shall be wired in a manner to ensure proper maintenance. Flexible electrical conduit and sufficient wire leads to remove the UV device are required.
2. The property owner must:
 - A. Record a notice to title informing the future property owner(s) that the UV disinfection device shall be maintained in working order for the life of the OSS.